



Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:

Director General

State Disaster Response & Fire Services

Andhra Pradesh, Vijayawada.

To:

District Educational Officer,

File No: 31159/VSP/MSB/2026, Date:13/04/2026Occupancy NoC RC Number: 26061/VSP/MSB/2025

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Multi Storeyed Building of **M/S. BALAJI HIGH FIELDS SCHOOL (BALAJI EDUCATIONAL SOCIETY)**, represented by **M. VANI**, SITUATED AT PULAGALIPALEM VILLAGE, GVMC, VISAKAPATANAM - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 26061/VSP/MSB/2025, Dt.24/04/2025
 4. Renewal NOC For Occupancy 26061/VSP/MSB/2025, Dt.24/04/2025
 5. Online Application for Renewal NOC of M. VANI, SITUATED AT PULAGALIPALEM VILLAGE, GVMC, VISAKAPATANAM - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 09-04-2026.

-- X --

The Management of M/S. BALAJI HIGH FIELDS SCHOOL (BALAJI EDUCATIONAL SOCIETY), represented by M. VANI, SITUATED AT PULAGALIPALEM VILLAGE, GVMC, VISAKAPATANAM has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.175680/- vide challan No. 10001769132026, Dated 04/04/2026 at ONLINE, ONLINE.

M/S. BALAJI HIGH FIELDS SCHOOL (BALAJI EDUCATIONAL SOCIETY)

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **M. VANI SITUATED AT PULAGALIPALEM VILLAGE, GVMC, VISAKAPATANAM**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

GENERAL MANAGER
BALAJI HIGHFIELDS SCHOOL
JUBILEE CAMPUS
PENDURTHI

SECRETARY
BALAJI EDUCATIONAL SOCIETY
GOPALAPATNAM
VISAKHAPATNAM

PRINCIPAL
Balaji Highfields School
Jubilee Campus
Pendurthi
Visakhapatnam



3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 25/04/2026 to 24/04/2031.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
10001769132026	2026-04-04	175680

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

Nil.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely,

Digitally Signed by,
VENKATA RAMANA PENIKALAPATI
Date: 13/04/2026 15:10:13

Director of Fire Services, (Technical)

Holding Full Additional charge of the Post of

Director General,

State Disaster Response and Fire Services,

Andhra Pradesh, Vijayawada

In case of emergency, please call 101 or 0891-2558470 or 9963729367

Copy to M. VANI, The Management of M/S. BALAJI HIGH FIELDS SCHOOL (BALAJI EDUCATIONAL SOCIETY), SITUATED AT PULAGALIPALEM VILLAGE, GVMC, VISAKAPATANAM

Copy to Chief Office for Record Purpose

Copy to Regional Fire Officer Concerned

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

GENERAL MANAGER
BALAJI HIGH FIELDS SCHOOL

SECRETARY
BALAJI EDUCATIONAL SOCIETY
GOPALAPATNAM
VISAKHAPATNAM

PRINCIPAL
Balaji Highfields School
Jubilee Campus
Pendurthi
Visakhapatnam